



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2006387
Permit #: 01569-2024CAT
Request Rec'd: 12/05/2024
Approval Date: 12/05/2024 DS
Permit Expires: 06/05/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Village of Lansing 3141 Ridge Road Lansing, IL 60438 Cook County Contact: Brian Hanigan 708/895-7205	FACILITY - name and address where tanks are located: Public Works Department 3300 171st Street Lansing, IL 60438 Cook County Contact: Gary Richardson 708/895-7190
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	8,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

INSTALL ADDITIONAL MAG ANODES ON DSL VENT PIPING AND A STRUCTURE TO SOIL POTENTIAL SURVEY BE CONDUCTED

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely,

Daniel Starks