

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2021161
Permit #: 01600-2024UPG
Request Rec'd: 12/11/2024
Approval Date:12/11/2024 DS
Permit Expires: 06/11/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

RDK Ventures, LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County

Contact: Elizabeth Sauser 773/456-5280

**FACILITY** 

- name and address where tanks are located:

Circle K #6721 100 Northwest Highway Barrington, IL 60010 Lake County

Contact: Dino Pappas 812/379-9227

#### Tanks on the Permit

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4      | Gasoline - Regular | 12,000   | Currently in use | Federal          |

### **Tank 4 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping                     | Other Steel Riser        | New   |
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Double Wall Spill Bucket |

## **Summary of Work**

Installing new fill riser on "Primary" Regular Tank# 4 and replacing overspill bucket, overfill drop tube

#### **Special Contingencies**

Janiel y. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: keith@andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks