



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2025664
Permit #: 01610-2024UPG
Request Rec'd: 12/12/2024
Approval Date: 12/12/2024 DS
Permit Expires: 06/12/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Groot, Inc., a subsidiary of Groot Industries, Inc. 3 Waterway Square Place, Suite 110 The Woodlands, TX 77380 Montgomery County Contact: Lana Brown 563/529-5524 | FACILITY - name and address where tanks are located: Groot Aurora 1565 Aurora Avenue Lane Aurora, IL 60505 Kane County Contact: Rodney Huguley 630/918-0924 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 4 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|--|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS - 4c | Replacing - Leak Detect - Tank - Automatic Tank Gauging Red Jacket ST 1401 |


Summary of Work

Replacing existing Red Jacket ST1400 ATG with Veeder Root TLS 4c and Veeder Root Mag 1 Probe (846397-107).

Special Contingencies

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154 | Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2025 |

Sincerely,



Daniel Starks