



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2018605  
Permit #: 01581-2024UPG  
Request Rec'd: 12/08/2024  
Approval Date: 12/09/2024 DS  
Amended Date: 12/19/2024 DS  
Permit Expires: 06/10/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 (None) County Contact: Bonnie Parrino 440/808-7268	<b>FACILITY</b> - name and address where tanks are located: Morris Travel Center 21 Romines Drive Morris, IL 60450 Grundy County Contact: Donna Barnard 815/942-5690
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	12,000	Currently in use	Federal
18	New Oil	8,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

replace Tank 18 spill bucket with new double wall

**Special Contingencies**

**Amendment Reason:**

Tank numbers differ from ATG at site to actual Tank number on portal. Changing paperwork to match portal.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/632-0440 Email: service@hci4.com Contractor License # IL646 Exp. 7/3/2026

Sincerely,



Daniel Starks