

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2028438
Permit #: 01637-2024UPG
Request Rec'd: 12/19/2024
Approval Date:12/19/2024 DS
Permit Expires: 06/20/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

9754 Irving Park Real Estate, LIC

9754 Irving Park Road Schiller Park, IL 60176

(None) County

Contact: Justin Kannalayil 224/578-3055

FACILITY

- name and address where tanks are located:

Schiller Park Mobil

9754 Irving

Schiller Park, IL 60176

Cook County

Contact: Justin Kannalayil 224/578-3055

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	6,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket Insert

Summary of Work

The spill bucket failed so replacing it

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services

4075 Fox Valley Center Dr., Unit 9

Vaniel J. Starke

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722

Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks