

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 2-023811
Permit # 00043-2007UPG
Request Rec'd 01/08/2007
Amended Date
Approval Date 1/9/2007 JC
Permit Expires 7/9/2007

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Commanding Officer Naval Station 2601 A. Paul Jones Street, Great Lakes, IL 60088-5000	NTC Environmental Dept 201 Decatur Ave,Bldg 1-A Great Lakes, Lake Co., IL
Contact: Mark Schultz	Contact: Conrad Dziewulski (847) 688-5999 Ext. 153

## (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 47) 15,000 gallons, (TK # 48, 49) 12,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 47, 48, 49) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass (TK # 49) There will be no product piping installed for this tank other than a siphon bar connecting it to tank #48.
- (d) Product to be stored in each tank: (TK # 47, 48, 49) Gasoline
- (e) Type of leak detection being used:
  - *Tank:* (TK # 47, 48, 49) (Installing) OPW EECO 1500 interstitial tank sensor, (TK # 47, 48, 49) (Installing) OPW EECO 1500 automatic tank gauge (TK # 47, 48, 49) There will only be ATG probes installed in these tanks for inventory purposes only.
  - **Piping:** (TK # 47, 48) (Installing) FE Petro STP-MLD mechanical line leak detector, (TK # 47, 48, 49) (Installing) OPW EECO 1500 interstitial piping sump sensors(TK # 47, 48, 49) Interstitial sensors will be installed at all dispenser sumps and all submersible sumps.
- (f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration #	Exp.

Sincerely,

Janu f Coffey

Division File (Rev. - 1/98)