

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2027061
Permit #: 01647-2024UPG
Request Rec'd: 12/10/2024
Approval Date:12/23/2024 DS
Permit Expires: 06/24/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Chicago Executive Airport 1020 South Plant Road Wheeling, IL 60090 Cook County

Contact: Tim Latendresse 847/537-1200

**FACILITY** 

- name and address where tanks are located:

Chicago Executive Airport 1020 South Plant Road Wheeling, IL 60090 Cook County

Contact: Tim Latendresse 847/537-2580

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	8,000	Currently in use	Federal
5	Diesel Fuel	12,000	Currently in use	Federal

### **Tank 4 Equipment**

Equipment Type	Permit Equipment	Action	
Leak Detection - Piping	Sump Sensor with positive shutdown	New	
Leak Detection Tiping	in Single Wall STP/Tanktop Sump	IVCVV	

#### **Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

# **Summary of Work**

Install positive shutdown for sump sensors.

Oaniel J. Starke

## **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:			
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: yvonne@crownetank.com Contractor License # IL002345 Exp. 5/16/2026		

Sincerely.

Daniel Starks