

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 4023993
Permit #: 01653-2024CAT
Request Rec'd: 12/24/2024
Approval Date:12/24/2024 DS
Permit Expires: 06/24/2025

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County

Contact: Elizabeth Sauser 773/456-5280

**FACILITY** 

- name and address where tanks are located:

Circle K #4700129 1903 West Market Street Bloomington, IL 61701 McLean County

Contact: Elizabeth Patterson 812/379-9227

### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

# Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

## **Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

# **Special Contingencies**

#### **Summary of Work**

Add suplemental sacrificial anodes to PUL and RUL tanks (both 10,000 gallon) to bring tanks back into compliance.

PERSON, FIRM OR COMPANY PERFORMING WORK:		
Berkeley Springs Instruments LLC 1 Quantum Circle Frostburg, MD 21532	Contact Person: Tina Lewis Phone: 262/720-6888 Email: james.davis@bsisentry.com Contractor License # IL002467 Exp. 8/20/2026	

Sincerely, Carrief J. Starks

Daniel Starks