



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2034817
Permit #: 01506-2024UPG
Request Rec'd: 11/21/2024
Approval Date: 11/21/2024 DS
Amended Date: 12/29/2024 DS
Permit Expires: 05/21/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231 | FACILITY - name and address where tanks are located: Bucky's Express #6533 1290 So. Route 59 Naperville, IL 60566 Du Page County Contact: Praful Chokshi 515/446-6238 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 20,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 15,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|---|---|
| Overfill Prevention Device | Ball Only Removed Ball Float Vent Valve | Removing |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping | Flexible Double Wall A.P.T. Poly Tech | Replacing - Piping - Flexible Double Wall |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|---|---|
| Overfill Prevention Device | Ball Only Removed Ball Float Vent Valve | Removing |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping | Flexible Double Wall A.P.T. Poly Tech | Replacing - Piping - Flexible Double Wall |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 3/4 | Sump / Sensors Changing |
| 5/6 | Sump / Sensors Changing |
| 7/8 | Sump / Sensors Changing |
| 9/10 | Sump / Sensors Changing |
| 11/12 | Sump / Sensors Changing |
| 13/14 | Sump / Sensors Changing |
| 15/16 | Sump / Sensors Changing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Dispenser 15/16 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Replacing - Leak Detect - Piping - Sump Sensor |

Summary of Work

New tank tops. Replacing all tank top equipment including submersibles and risers.

Special Contingencies


NOTE: A removal permit is required to replace the piping.

Amendment Reason:

Replacing all dispenser sumps and pipe.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 815/520-5292 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,



Daniel Starks