



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3024494
Permit #: 01658-2024CAT
Request Rec'd: 12/27/2024
Approval Date: 12/29/2024 DS
Permit Expires: 07/01/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lake Archer Real Estate, LLC 4111 Emporia Court Naperville, IL 60564 (None) County Contact: Mursaleen Lawai 630/639-6461	FACILITY - name and address where tanks are located: Knoxville & Archer Ave., Inc. 2312 N Knoxville Road Peoria, IL 61604 Peoria County Contact: Aslam Khan 630/841-8012
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	8,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Replacing sacrificial anodes on steel flex connectors and piping at submersible pump containment sumps due to failed testing.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Cheri McCoy
Phone: 309/694-8224
Email: Tom.Oltman@TotalPetroleum.net
Contractor License # IL1079 Exp. 2/8/2026

Sincerely,



Daniel Starks