



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3009305  
Permit #: 01660-2024CAT  
Request Rec'd: 12/27/2024  
Approval Date: 12/29/2024 DS  
Permit Expires: 07/01/2025

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|   |   |
|---|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Sherpa Properties, LLC<br>608 E. Jackson Street<br>Macomb, IL 61455<br>(None) County<br>Contact: Prabin Gautam 720/278-5912 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Sherpa Stop<br>608 E. Jackson Street<br>Macomb, IL 61455<br>McDonough County<br>Contact: Prabin Gautam 720/278-5912 |
|---|---|

**Tanks on the Permit**

| Tank # | Product              | Capacity | Tank Status      | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 6      | Gasoline - Premium   | 10,000   | Currently in use | Federal          |
| 7      | Gasoline - Mid-grade | 10,000   | Currently in use | Federal          |

**Tank 6 Equipment**

| Equipment Type                | Permit Equipment                       | Action   |
|-------------------------------|--|--|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - STP | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP |

**Tank 7 Equipment**

| Equipment Type                | Permit Equipment                       | Action   |
|-------------------------------|--|--|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - STP | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP |

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

STP CONTAIN WATER AND THE CP THAT WAS ON THEM HAD FAILED. WE ADDED NEW ANODES TO BOTH STP'S TO BRING THE READINGS BACK UP.

|   |  |
|---|--|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>         |  |
| Pipeco, Inc.<br>610 29th Street<br>Bettendorf, IA 52722 | Contact Person: Robert Schafer<br>Phone: 563/344-0700<br>Email: lynn@pipecoinc.com<br>Contractor License # IL2034 Exp. 9/28/2026 |

Sincerely,

*Daniel J. Starks*

Daniel Starks