



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2042220
Permit #: 00007-2025ABN
Request Rec'd: 12/31/2024
Approval Date: 01/04/2025 DS
Permit Expires: 07/05/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 (None) County Contact: Jeremy Holland 610/625-8061	FACILITY - name and address where tanks are located: IL0103 5151 Sauk Trail Richton Park, IL 60471 Cook County Contact: Jim E. Peters 847/680-5831
--	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
3	6,000	E85	Tripolymer Foam

Explanation of Waiver for Abandonment

Tank is part of a compartment tank split with premium. T3 E85 is tank to be abandoned. Premium tank to stay in service.

Gabriel Environmental completed site assessment on 12/19/2024

CONTAMINATED SITE!

IEMA Number
2024-0954

Tripolymer Foam Information

Buoyancy Calculations

See Buoyancy Calculation files attached to the permit application.

Protections Against UST Flotation

Based off the buoyancy calculations the backfill and overburden material will keep the tank from floating. In addition the buoyancy calculation did not include the tank weight or product weight of fuel in the premium tank which will provide additional protection from floatation.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/978-9937 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2026

Sincerely,

Daniel J. Starks

Daniel Starks