



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016095
Permit #: 00017-2025UPG
Request Rec'd: 12/24/2024
Approval Date: 01/07/2025 SK
Permit Expires: 07/08/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sheridan Road , LLC 7300 N. St. Louis Ave. Skokie, IL 60076 Cook County Contact: Greg Polan 847/674-0090	FACILITY - name and address where tanks are located: Alltown Bus/Sheridan Road, LLC 8121-8133 S. Dobson Avenue Chicago, IL 60619 Cook County Contact: Greg Polan 847/674-0090
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	10,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Summary of Work

Beacon will replace the existing OPW EECO 1500 ATG with a Veeder Root TLS 300 ATG with a Veeder Root Tank Intertitial Sensor. We will also replace the exisitng OPW In-tank Probe with a Veeder Root 846390-107 In-tank Probe.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2025

Sincerely,

Sean Keane