

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2023047
Permit #: 00018-2025UPG
Request Rec'd: 01/07/2025
Approval Date:01/07/2025 DS
Permit Expires: 07/08/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

1805, Inc. and EGVS, Inc.

1805 E. Oakton Elk Grove, IL 60007

Cook County

Contact: George Neoiyakmayil 847/910-1068

**FACILITY** 

- name and address where tanks are located:

1805, Inc. & EGVS, Inc. 1805 East Oakton

Elk Grove Village, IL 60007

Cook County

Contact: Shobi Qureshi 847/910-1068

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Regular	18,000	Currently in use	Federal
10	Gasoline - Premium	7,000	Currently in use	Federal
11	Diesel Fuel	11,000	Currently in use	Federal

#### **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

#### **Tank 10 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

## **Tank 11 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

#### **Summary of Work**

Changing the spill buckets and drop tubes for regular, premuim and Diesel. Drop tubes were stuck to the risers, so we need to digdown to the tank top to change the risers.

Thnak you

**Innovative Constructions** 

#### **Special Contingencies**

## PERSON, FIRM OR COMPANY PERFORMING WORK:

Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185

Daniel J. Starke

Contact Person: Raju penumatsa Phone: 630/747-3404

Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Daniel Starks