

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1037269
Permit #: 00019-2025UPG
Request Rec'd: 01/07/2025
Approval Date:01/07/2025 DS
Permit Expires: 07/08/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Conserv FS, Inc. 1110 McConnell Road Woodstock, IL 60098 McHenry County

Contact: David Myroth 815/709-7915

FACILITY

- name and address where tanks are located:

Waterman 9391 Route 23 Waterman, IL 60556 De Kalb County

Contact: Michael Glendenning 630/774-7457

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 1 | Diesel Fuel | 6,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Alarm | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing overspill bucket to new dw overspill. Replacing overfill valve to overfill alarm.

Vaniel J. Starke

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | | | |
|--|--|--|--|--|
| Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704 | Contact Person: TJ Winkler Phone: 815/298-3767 Email: pobrien@oilequipment.com Contractor License # IL1318 Exp. 11/13/2026 | | | |

Sincerely,

Daniel Starks