



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2002280
Permit #: 00969-2024UPG
Request Rec'd: 08/05/2024
Approval Date: 08/12/2024 DS
Amended Date: 01/08/2025 DS
Permit Expires: 02/13/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Des Plaines Valley Mosquito Abatement Dist. 8130 Ogden Ave Po Box 31 Lyons, IL 60534 Cook County Contact: Robert Holub 708/447-1765	FACILITY - name and address where tanks are located: Des Plaines Valley Mosquito Abatement Dist. 8130 Ogden Ave. P.O. Box 31 Lyons, IL 60534 Cook County Contact: Robert E. Holub 708/447-1765
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	European with No Test Req Suction	Replacing - Leak Detect - Piping - European with No Test Req Suction
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Dispensers on the Permit

Dispenser	Action
1	Sump / Sensors Changing
2	Sump / Sensors Changing
3	Removing

Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Summary of Work

We will be upgrading Tank # 1 by installing new Bravo single wall containment sump. We will be install new single wall UDC sumps under dispensers 1 & 2. We will be replacing existing single wall fiberglass suction piping and installing new Ameron 2" LCX double wall suction piping.

We will install OPW vertical check valve 70S-0075 under each dispenser.

We will be upgrading existing suction dispensers to new Gasboy Atlas Suction pumps

We will relocate existing overspill on tank 1 from existing location to different bung on tank shown on drawing. We will upgrade to new OPW 1C 3112P double wall edge overspill 5 gallon

Special Contingencies**Amendment Reason:**


Installing new spill bucket

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/606-0996
Email: nickb@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------