



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4010379
Permit #: 00027-2025CAT
Request Rec'd: 01/07/2025
Approval Date: 01/10/2025 DS
Permit Expires: 07/10/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231 | FACILITY - name and address where tanks are located: Casey's General Store #2930 300 S. Century Blvd. Rantoul, IL 61866 Champaign County Contact: Virginia Ford 217/893-8844 |
|--|---|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 3 | E85 | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|----------|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Removing |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|----------|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Removing |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|----------|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Removing |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Removing Sacrificial Anodes from STP's. Not Listed on the equipment listing. Site does not have Impressed Current on Piping except for Tank Vent Piping. Piping is Non Corrosive Fiberglass. Will be removing after Neumayer has done the required work to insure STP's are water tight

PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC
2008 Medical Center Dr
Monticello, IL 61856

Contact Person: Stephen T. Hall
Phone: 217/714-4305
Email: midwesttanktestingsth@aol.com
Contractor License # IL002461 Exp. 1/2/2026

Sincerely,



Daniel Starks