



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021198
Permit #: 00047-2025UPG
Request Rec'd: 01/15/2025
Approval Date: 01/16/2025 DS
Permit Expires: 07/16/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures, LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Elizabeth Sauser 773/456-5280	FACILITY - name and address where tanks are located: Circle K #6720 681 Terra Cotta Avenue Crystal Lake, IL 60014 McHenry County Contact: Denice Wright 812/379-9227
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Diesel Fuel	12,000	Currently in use	Federal
7	Gasoline - Premium	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispensers on the Permit

Dispenser	Action
7/8	Sump / Sensors Changing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing


Summary of Work

Removing and Installing new single wall UDC sump at dispenser 7/8. No more than 2" of each product line will be replaced.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks