



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7034761
Permit #: 00056-2025ABN
Request Rec'd: 01/20/2025
Approval Date: 01/21/2025 DS
Permit Expires: 07/22/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Payne Service Center, Inc. 21363 Shawneetown Road Thompsonville, IL 62890 Franklin County Contact: Mith Mevada 618/627-2781	FACILITY - name and address where tanks are located: Payne Service Center, Inc. 21363 Shawneetown Road Thompsonville, IL 62890 Franklin County Contact: Mith Mevada 618/627-2781
---	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
4	6,000	Gasoline - Premium	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Tank is located in the same excavation as the other tanks that will remain in use. Piping will be abandoned also. Piping is assumed to be located in the same trenches as the other piping.

Location of Tanks Being Abandoned

Tank is located in the same excavation as the other tanks that will remain in use. Piping will be abandoned also. Piping is assumed to be located in the same trenches as the other piping.

Location of Piping Being Abandoned

Tank is located in the same excavation as the other tanks that will remain in use. Piping will be abandoned also. Piping is assumed to be located in the same trenches as the other piping.

CONTAMINATED SITE!

IEMA Number

2018-1161

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel J. Starks

Daniel Starks