



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2020700  
Permit #: 00058-2025UPG  
Request Rec'd: 11/13/2024  
Approval Date: 01/22/2025 SK  
Permit Expires: 07/22/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: City of Chicago Department of Water Management 1000 East Ohio Street Commissioner's Office Chicago, IL 60611 Cook County Contact: Harold Keaton 312/747-7154	<b>FACILITY</b> - name and address where tanks are located: City of Chicago Department of Water Management 3300 S. Cheltenham Place Chicago, IL 60649 Cook County Contact: Harold Keaton 312/747-7154
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Diesel Fuel	8,000	Currently in use	Federal

**Tank 11 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Leak Detection - Piping	American with Sensors/No Test Suction	Replacing - Leak Detect - Piping - American with Annual Prec Line Testing Suction
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Aboveground	Removing
Piping	Fiberglass Chase	Removing
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Steel Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Installing new tank top sump.  
Replacing the fuel supply and return piping from tank to building.  
Replacing vent line to building.  
Installing a new double wall overspill container and overfill valve.  
Reusing the sump sensor, probe and veeder root console.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026

Sincerely,

Sean Keane