



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5020729
Permit #: 00066-2025ABN
Request Rec'd: 01/24/2025
Approval Date: 01/24/2025 DS
Permit Expires: 07/24/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Seaugh 502/572-1259	FACILITY - name and address where tanks are located: Thorntons #367 420 W. Dearborn Havana, IL 62644 Mason County Contact: Evon Turner 309/543-4482
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
5	10,000	Gasoline - Premium	Inert material mixed with portland cement
6	10,000	Gasoline - Regular	Inert material mixed with portland cement
7	10,000	Gasoline - Regular	Inert material mixed with portland cement
8	10,000	Gasoline - Mid-grade	Inert material mixed with portland cement
9	10,000	Diesel Fuel	Inert material mixed with portland cement
10	4,000	Kerosene	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Tanks are within the shaded area of the attachment. Extend within 5 feet of the store and the neighbors building and property. Can not safely remove without disturbing foundation.

Will be filing 2 more permits. One for pipe removal and one for a new tank and piping install.

Location of Tanks Being Abandoned

Tanks are in close proximity to the building (3') as shown in attached drawing. Attempting to remove the tanks would undermine the structural integrity of the building.

Special Contingencies

NOTE: A separate removal permit will be submitted for the removal of the product piping.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 515/601-6635 Email: jfranklin@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

Daniel J. Starks

Daniel Starks