



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5020729
Permit #: 00067-2025REM
Request Rec'd: 01/24/2025
Approval Date: 01/24/2025 DS
Permit Expires: 07/24/2025

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Seauth 502/572-1259	FACILITY - name and address where tanks are located: Thorntons #367 420 W. Dearborn Havana, IL 62644 Mason County Contact: Evon Turner 309/543-4482
--	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
5	10,000	Gasoline - Premium	
6	10,000	Gasoline - Regular	
7	10,000	Gasoline - Regular	
8	10,000	Gasoline - Mid-grade	
9	10,000	Diesel Fuel	
10	4,000	Kerosene	

Summary of Work

Remove existing piping from previous abandoned tanks along with vent lines. Preparing for a new install
No existing asbuilts available so this is our best guess of piping routes.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 515/601-6635 Email: jfranklin@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

Daniel J. Starks

Daniel Starks