



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 7035519 |
| Permit #: | 00068-2025UPG |
| Request Rec'd: | 01/24/2025 |
| Approval Date: | 01/24/2025 DS |
| Permit Expires: | 02/04/2025 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| <p>OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231</p> | <p>FACILITY - name and address where tanks are located: Caseys General Stores #1947 100 Highland Avenue Fairfield, IL 62837 Wayne County Contact: Sherri Hicks 515/965-6238</p> |
|--|--|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--|--|
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron Dualoy 3000/L | Replacing - Piping - Fiberglass Single Wall Piping |

Summary of Work

upgrade after emergency is approved to repair 2" main fiberglass line at the sump wall. It is leaking and need to jack hammer on outside of sump and then dig and replace 1' of pipe into sump.

REPLACED 2" MAIN FIBERGLASS LINE AT SUMP WALL

1' OF PIPE INTO SUMP

WAS DAMAGED

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| <p>Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139</p> | <p>Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026</p> |

Sincerely,

Daniel Starks