



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-007826
Permit # 01910-2006UPG
Request Rec'd 12/14/2006
Amended Date
Approval Date 12/21/2006 JC
Permit Expires 6/21/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: IL Bell Telephone Co. d/b/a SBC Illinois 36 S. Fairview, 4th Floor Park Ridge, IL 60068-4016 Contact: Environmental Management (877) 648-2073	(2) FACILITY - name and address where tanks are located: SBC/Ameritech Cicero Co Q22100 6125 W. 26th Street Cicero, Cook Co., IL Contact: Environmental Management (877) 648-2073
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 4) - 6,000 gallons
- (b) **Type of tanks:** (TK # 4) Existing Existing double wall fiberglass
- (c) **Type of piping:** (TK # 4) - (Installing) Steel primary with fiberglass secondary, (TK # 4) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass, (TK # 4) Existing Existing steel primary within fiberglass secondary (TK # 4) - Piping (supply and return) is being replaced from tank sump #1 to the generator outside of the building. The primary piping will be schedule 40 black steel. The secondary will be Ameron Dualoy 3000L.
- (d) **Product to be stored in each tank:** (TK # 4) - Diesel Fuel
- (e) **Type of leak detection being used:**
Tank: (TK # 4) Existing Existing automatic tank gauging, (TK # 4) Existing Existing interstitial monitoring
Piping: (TK # 4) - Existing interstitial monitoring, (TK # 4) Existing Existing European Suction (TK # 4) - Interstitial sensors are located at both tank sumps. Piping is a suction system.
- (f) **Corrosion Protection being used:**
Tank:
Piping: (TK # 4) Existing Existing composite secondary
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Phone: Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File

