



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	4029138
Permit #:	00062-2025UPG
Request Rec'd:	01/22/2025
Approval Date:	01/22/2025 DS
Amended Date:	01/29/2025 DS
Permit Expires:	08/05/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Alam Oil Company P.O. Box 279 Danvers, IL 61732 McLean County Contact: Alex Alam 847/917-6796	FACILITY - name and address where tanks are located: Denver's Fast Stop 100 E. Exchange Street Danvers, IL 61732 McLean County Contact: Teri Goembel 309/963-3993
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New

Summary of Work

Due to contractor that is adding onto building hit the vent line we had to make an emergency repair on it. Once the new building addition is done we will reroute the vent lines. See drawing attached.
The building is being expanded 10 feet. The new vent stand will be attached to the building just like before but on the end of the building nearest the tanks. Vents will be temporarily stubbed up 12' above grade and secured while construction on building takes place. After exterior of building is complete, IOME will extend vent piping approximately 8 feet to new vent stand location. Bollards will be used as collision protection.

Special Contingencies

NOTE: This emergency repair permit is ONLY to fix the section of piping that was damaged. The re-routing of the vent piping must be done under a separate upgrade permit.

Amendment Reason:

IOME is not replacing piping exceeding 20 feet or 50%. Box was marked incorrectly. Permit schedule indicates primary, secondary and containment. Only small section of vent piping is being re-routed. Vent piping doesn't have secondary and nothing needing containment testing was touched. Thank you

PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: 309/657-0058
Email: bestes@iome.com
Contractor License # IL1293 Exp. 2/4/2026

Sincerely,



Daniel Starks