



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2044558  
Permit #: 00099-2025UPG  
Request Rec'd: 01/29/2025  
Approval Date: 01/30/2025 DS  
Permit Expires: 07/30/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Ralph's Grocery Company d/b/a Food 4 Less, a sub. Kroger Co. 7770 S. Cicero Avenue Burbank, IL 60459 Cook County Contact: Joe Harley 708/499-7983	<b>FACILITY</b> - name and address where tanks are located: Food 4 Less #560 2525 W. North Ave. Melrose Park, IL 60160 Cook County Contact: Greg Noble 310/884-4011
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	8,000	Currently in use	Federal
3	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53VML	Removing

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53VML	Removing

**Summary of Work**

Removing ball floats, converting multiport fill/vapor to direct bury

**Special Contingencies**

**NOTE: Site has existing overfill alarm**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/520-5292 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks