



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3024552
Permit #: 00106-2025CAT
Request Rec'd: 01/31/2025
Approval Date: 02/03/2025 DS
Permit Expires: 08/05/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Naginder Singh 3520 5th Street East Moline, IL 61244 Rock Island County Contact: Naginder Singh 309/582-3334 | FACILITY - name and address where tanks are located: Moline Gas Food and Liquor 3328 Avenue of the Cities Moline, IL 61265 Rock Island County Contact: Naginder Singh 309/337-7376 |
|--|---|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|------------------------|----------|----------------|------------------|
| 1 | Gasoline - Non Ethanol | 10,000 | Out of service | Federal |
| 2 | Gasoline - Regular | 10,000 | Out of service | Federal |
| 3 | Gasoline - Premium | 6,000 | Out of service | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - Dispenser 1/2 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 1/2 |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - Dispenser 3/4 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 3/4 |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - Dispenser 5/6 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 5/6 |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Adding sacrificial anodes to flex connectors in dispenser UDC and STP containment sump.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Berkeley Springs Instruments LLC
1 Quantum Circle
Frostburg, MD 21532

Contact Person: Tina Lewis
Phone: 262/720-6888
Email: james.davis@bsisentry.com
Contractor License # IL002467 Exp. 8/20/2026

Sincerely,



Daniel Starks