



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4027400
Permit #: 00122-2025ABN
Request Rec'd: 01/31/2025
Approval Date: 02/03/2025 DS
Permit Expires: 08/05/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Watseka, Inc. 408 N. Dixie Hwy. Momence, IL 60954 Kankakee County Contact: Kulwinder Singh 815/383-8503	FACILITY - name and address where tanks are located: M J. Food Mart, LLC 1150 East Walnut Watseka, IL 60970 Iroquois County Contact: Manjo 815/432-6064
---	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
2	12,000	Gasoline - Regular	Inert material mixed with portland cement
4	4,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Since these tanks are middle of other two tanks which are functional, we really can not remove these tanks by keeping the existing tanks.

Please approve this because of other tanks in place

Thank you

Innovative Constructions

Location of Tanks Being Abandoned

Tanks are located in an active tank field, as shown in site plan.

Location of Piping Being Abandoned

No piping shown or mentioned in scope of work. Piping must be removed under a separate removal permit or tied into existing piping under a separate upgrade permit.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185	Contact Person: Raju penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Daniel J. Starks

Daniel Starks