



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2020700
Permit #:	00058-2025UPG
Request Rec'd:	11/13/2024
Approval Date:	01/22/2025 SK
Amended Date:	02/04/2025 SK
Permit Expires:	07/22/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: City of Chicago Department of Water Management 1000 East Ohio Street Commissioner's Office Chicago, IL 60611 Cook County Contact: Harold Keaton 312/747-7154	FACILITY - name and address where tanks are located: City of Chicago Department of Water Management 3300 S. Cheltenham Place Chicago, IL 60649 Cook County Contact: Harold Keaton 312/747-7154
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	#2 Fuel Oil	8,000	Currently in use	Federal

Summary of Work

Installing new tank top sump.
Replacing the fuel supply and return piping from tank to building.
Replacing vent line to building.
Installing a new double wall overspill container and overfill valve.
Reusing the sump sensor, probe and veeder root console.

Special Contingencies

Amendment Reason:

The wrong number tank is reflected on the permit. Tank #10 is being upgraded not #11.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026

Sincerely,

Sean Keane