



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3017885  
Permit #: 00130-2025UPG  
Request Rec'd: 02/05/2025  
Approval Date: 02/05/2025 DS  
Permit Expires: 08/05/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: American Liquor & Food Mart 1218 Peoria Street Washington, IL 61571 Tazewell County Contact: Pradeep Kataria 309/243-1908	<b>FACILITY</b> - name and address where tanks are located: American Liquor & Foodmart, LLC 1218 Peoria Street Washington, IL 61571 Tazewell County Contact: Jarnail Singh 309/243-1908
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Premium	10,000	Currently in use	Federal
8	Gasoline - Mid-grade	10,000	Currently in use	Federal

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Replacing spill manholes due to failed testing.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026

Sincerely,



Daniel Starks