

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2021045
Permit #: 00131-2025UPG
Request Rec'd: 02/05/2025
Approval Date:02/05/2025 SK
Permit Expires: 02/19/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

300 S. Cicero Bldg., LLC 17508 Brook Crossing Orland Park, IL 60467 (None) County

Contact: Mohammed Abdallah 773/447-2771

FACILITY

- name and address where tanks are located:

Falcom Fuel 300 S. Cicero Avenue Chicago, IL 60644 Cook County

Contact: Saleh 708/655-4837

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 15,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|-------------------------------------|--------|
| Piping | Ball Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Galvanized Steel Single Wall Piping | New |

Summary of Work

Failed flex connector, galvanized pipe nipple and ball valve will be replaced in the Regular tank pump sump.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | | | |
|---|--|--|--|--|
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: ed.angell@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 | | | |

Sincerely,

Sean Keane