



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2020700
Permit #:	00057-2025ABN
Request Rec'd:	01/17/2025
Approval Date:	01/22/2025 SK
Amended Date:	02/05/2025 SK
Permit Expires:	07/22/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: City of Chicago Department of Water Management 1000 East Ohio Street Commissioner's Office Chicago, IL 60611 Cook County Contact: Harold Keaton 312/747-7154	FACILITY - name and address where tanks are located: City of Chicago Department of Water Management 3300 S. Cheltenham Place Chicago, IL 60649 Cook County Contact: Harold Keaton 312/747-7154
--	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
2	8,000	#2 Fuel Oil	Inert material mixed with portland cement
3	8,000	#2 Fuel Oil	Inert material mixed with portland cement
4	8,000	#2 Fuel Oil	Inert material mixed with portland cement
5	8,000	#2 Fuel Oil	Inert material mixed with portland cement
6	8,000	#2 Fuel Oil	Inert material mixed with portland cement
7	8,000	#2 Fuel Oil	Inert material mixed with portland cement
8	8,000	#2 Fuel Oil	Inert material mixed with portland cement
9	8,000	#2 Fuel Oil	Inert material mixed with portland cement
11	8,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

The removal of the tanks will disturb an adjacent tank that will remain in use.
The removal of the tanks may jeopardize the building foundation.

Special Contingencies

Amendment Reason:

Tanks to be abandoned are #2 - #9 & #11. Tank #10 will be upgraded under permit 00058-2025UPG .

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 9/8/2025

Sincerely,

Sean Keane