

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1013069
Permit #: 00133-2025UPG
Request Rec'd: 02/06/2025
Approval Date:02/06/2025 DS
Permit Expires: 08/06/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Petersen Fuels, Inc.

148 South State Street P.O. Box 398

Hampshire, IL 60140

Kane County

Contact: Les Petersen 847/683-2188

**FACILITY** 

- name and address where tanks are located:

Pete's Castle

104 West Main Street Genoa, IL 60135 De Kalb County

Contact: Corinne Peterson-Cork 815/784-4060

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	8,000	Currently in use	Federal
9	Diesel Fuel	4,000	Currently in use	Federal

### **Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

#### **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

## **Summary of Work**

Removing overfill valves from tanks 7 & 9. Installing straight drop tubes. Site has functional overfill alarm for overfill protection.

### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: TJ Winkler Phone: 815/298-3767 Email: pobrien@oilequipment.com Contractor License # IL1318 Exp. 11/13/2026			

Sincerely, Daniel J. Starke

Daniel Starks