

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 3037214
Permit #: 00143-2025UPG
Request Rec'd: 02/07/2025
Approval Date:02/07/2025 DS
Permit Expires: 08/07/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:

G & D Transportation, Inc.

50 Commerce Drive
Morton, IL 61550
Tazewell County

Contact: Oneill Bill 309/699-4556

FACILITY
- name and address where tanks are located:

G & D Transportation Inc

50 Commerce Drive
Morton, IL 61550
Tazewell County

Contact: Mitch Waller 309/699-4556

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Used Oil	2,500	Currently in use	Federal

### **Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Pneumercator LC1002	New
Leak Detection - Tank	Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor

#### **Summary of Work**

Replacing current OC panel with Pneumercator, installing new sump sensor and tank interstitial sensor on tank #1

#### **Special Contingencies**

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:			
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2026		

Sincerely,

Daniel Starks