



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY
Facility #: 2040743
Permit #: 00158-2025UPG
Request Rec'd: 02/12/2025
Approval Date: 02/13/2025 DS
Revision Date: 02/13/2025 DS
Permit Expires: 08/13/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Suson, LLC 2279 Stepstone Lane Hanover Park, IL 60133 Du Page County Contact: Bhaven Golwala 201/621-3612	FACILITY - name and address where tanks are located: Suson, LLC d/b/a Carol Stream Mobil 105 W. North Ave. Carol Stream, IL 60188 Du Page County Contact: Bhaven Golwala 630/933-8339
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Summary of Work

The entire pipe run between dispenser #11/12 and that dispensers transition sump for the Premium and Regular line will be removed and replaced with 2" diameter Ameron LCX rigid fiberglass pipe.

Special Contingencies

Revision Reason:

Changed from removing and installing new to "replacing" piping

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed.angell@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Daniel J. Starks

Daniel Starks