



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2012966
Permit #: 00077-2025UPG
Request Rec'd: 01/27/2025
Approval Date: 01/28/2025 DS
Amended Date: 02/15/2025 DS
Permit Expires: 07/29/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710 | FACILITY - name and address where tanks are located: Gages Lake #2 33978 N. US Hwy 45 Gages Lake, IL 60030 Lake County Contact: Mike Graham 847/223-3710 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 8 | Diesel Fuel | 10,000 | Currently in use | Federal |
| 9 | E85 | 2,000 | Currently in use | Federal |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------------------------|-------------------------------------------------------------|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------------------------|-------------------------------------------------------------|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing the existing STP Sumps on DSL & E85 tanks with new SWFRP STP Sumps. The existing STP Sump collars are to remain. Revising the existing DWFRP piping only as needed to replace the sumps. Reusing the existing sump sensors. Replacing the existing SW Spill bucket on E85 tank with new Franklin Defender DW Spill Bucket. Reusing the existing Overfill Valve.


Special Contingencies

Amendment Reason:

Replacing single wall Defender spill bucket, with double wall Defender @ Diesel tank 8. Diesel bucket is in same excavation as E85 STP sump.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|
| Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191 | Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2026 |

Sincerely,



Daniel Starks