



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023045
Permit #: 00182-2025UPG
Request Rec'd: 02/17/2025
Approval Date: 02/18/2025 SK
Permit Expires: 08/19/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 1950 RE, Inc. 1950 N. California Ave. Chicago, IL 60647 Cook County Contact: Timmy Joy 773/818-1738	FACILITY - name and address where tanks are located: JNT Fuels, Inc. 1950 N. California Ave. Chicago, IL 60647 Cook County Contact: Timmy Joy 773/818-1738
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	10,000	Currently in use	Federal
7	Gasoline - Regular	10,000	Currently in use	Federal
8	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	SIR and Prec Tightness Testing	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	SIR and Prec Tightness Testing	New

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	SIR and Prec Tightness Testing	New

Summary of Work

To accomodate a buiding remodel, the tank monitor will be removed until the building remodel has been completed. No product sales will be conducted during the building remodel.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed.angell@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,
Sean Keane