



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

<b>FOR OFFICE USE ONLY</b>	
Facility #:	1044567
Permit #:	00167-2025UPG
Request Rec'd:	02/14/2025
Approval Date:	02/15/2025 DS
Amended Date:	02/20/2025 DS
Permit Expires:	08/15/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: GPM Midwest, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Rolfe Lann 804/730-1568	<b>FACILITY</b> - name and address where tanks are located: Fas Mart #5179 6010 E. Riverside Loves Park, IL 61111 Winnebago County Contact: Amber Nicholson 815/815-4447
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53	Removing

**Summary of Work**

Installing new OPW Straight drop tube in the premium tank. Also removing the existing ball float from the premium tank.

**Special Contingencies**

**Amendment Reason:**

On this permit, I had listed an overfill valve going into the premium tank. I found out that they are installing a straight drop tube and using the alarm for overfill protection

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: TJ Winkler Phone: 608/354-1992 Email: msobczak@oilequipment.com Contractor License # IL1318 Exp. 11/13/2026

Sincerely,

Daniel Starks