



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3042761
Permit #:	00234-2025UPG
Request Rec'd:	02/27/2025
Approval Date:	02/27/2025 DS
Permit Expires:	08/27/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: West Central FS, Inc. 1445 Monmouth Blvd. Galesburg, IL 61401 Knox County Contact: Darin Weirather 309/627-2394	FACILITY - name and address where tanks are located: Williamsfield Fast Stop 218 Illinois Route 1-80 Williamsfield, IL 61489 Knox County Contact: Tricia Faudree 309/734-8391
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Piping	Flexible Double Wall A.P.T. Poly Tech	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P200SC

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P200SC	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P200SC

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
DSL Sat.	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Dispenser DSL Sat. Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Summary of Work

MANAFOLD TWO GAS LINES TOGETHER UNDER DISPENSERS. INSTALL SUMP SENSORS IN DISPENSER SUMP AND STP SUMPS WITH POSITIVE SHUTOFF. INSTALL NON VENTED SWITCH CHECK IN SUBMERGE PUMP FOR VEEDER ROOT PLLD

Special Contingencies

NOTE: Per section 175.450, after October 13, 2018, any product piping manifolded beneath a dispenser must be manifolded so that each line connecting to dispenser supply piping is on its own separate shear valve. Manifolding of lines shall not be done above the shear valve.

PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company
2923 Gardner Expressway P. O. Box 1086
Quincy, IL 62305

Contact Person: Marty Jackson
Phone: 217/223-2190
Email: kmajors@rlhoener.com
Contractor License # IL2021 Exp. 5/22/2026

Sincerely,



Daniel Starks

For Office Use Only**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing