



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2046837  
Permit #: 00247-2025UPG  
Request Rec'd: 03/03/2025  
Approval Date: 03/04/2025 SK  
Permit Expires: 09/04/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Chicago Travel Plaza LLC.<br>2900 Telestar Ct.<br>Falls Church, VA 22042<br>Contact: Joe Bishop 571/575-1234 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Chicago Travel Plaza LLC.<br>Building 840 O'Hare International Airport<br>Chicago, IL 60666<br>Cook County<br>Contact: Joe Bishop 571/575-1234 |
|--|--|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2      | Gasoline - Regular | 12,000   | Currently in use | Federal          |
| 7      | E85                | 12,000   | Currently in use | Federal          |

**Tank 2 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping                     | Other Steel Riser        | New   |
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Double Wall Spill Bucket |

**Tank 7 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping                     | Other Steel Riser        | New   |
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Double Wall Spill Bucket |

**Summary of Work**

Installing new fill risers, Replacing overspill buckets, overfill drop tubes, fill adapters and caps on Regular Tank# 2 and E-85 Tank# 7. \*\*\*I have submitted a Blended Fuel Compatibility Form on the OSFM Portal for E-85 Tank# 7\*\*\*

**Special Contingencies**

|  |  |
|--|--|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>                            |  |
| Anderson Pump Service, Inc.<br>19659 South 97th Avenue<br>Mokena, IL 60448 | Contact Person: Ron Anderson<br>Phone: 708/560-5590<br>Email: keith@andersonpump.com<br>Contractor License # IL002275 Exp. 5/21/2026 |

Sincerely,  
Sean Keane