



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2040347
Permit #: 00253-2025UPG
Request Rec'd: 03/04/2025
Approval Date: 03/04/2025 DS
Permit Expires: 09/04/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 495449428 Contact: Erik Petrovoskis 616/735-7101	FACILITY - name and address where tanks are located: Meijer Gas & C Store # 183 801 S. Randall Road Elgin, IL 60123 Kane County Contact: Scott Hacker 847/717-6500
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Kerosene	3,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - European with No Test Req Suction
Piping	Other Submersible Pump	New

Summary of Work

Converting Kerosene Suction System to Pressurized System
Replacing Suction Pump with a Dispenser

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. W. Mercer Company 2322 Brooklyn Road Jackson, MI 49203	Contact Person: Tracy Saylor Phone: 517/206-1946 Email: dean@rwmerc.com Contractor License # IL002211 Exp. 6/21/2025

Sincerely,

Daniel Starks