



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended/Amended

FOR OFFICE USE ONLY
Facility #: 2025667
Permit #: 00929-2024UPG
Request Rec'd: 08/05/2024
Approval Date: 08/05/2024 DS
Amended Date: 03/04/2025 DS
Extension Date: 02/01/2025
Permit Expires: 08/05/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Lake County Contact: Raymond Kirchner 847/837-0777	FACILITY - name and address where tanks are located: Johnsburg Quik Shop 3615 Chapel Hill Road Johnsburg, IL 60050 McHenry County Contact: Richard Snyder 847/837-0785
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	10,000	Currently in use	Federal
8	Gasoline - Regular	5,000	Currently in use	Federal
9	Gasoline - Premium	5,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Summary of Work

We will be replacing the existing STP sumps on all (3) tanks with new SWFRP STP sumps revising the existing SWFRP piping only as needed to replace the sumps. We will be replacing the existing submersible pumps with new FE Petro 2hp submersible pumps. We will be installing SWFRP UDC's at the (4) dispenser locations as shown revising the existing SWFRP piping only as needed to install the UDC's. We will also be replacing the existing Spill bucket & Overfill valve on the 5K RUL tank.

Note: Amending this permit to include the removal of buried unions in the vent piping on the 5K PUL & 5K RUL tanks. We cut the section of both vents piping and made a solid / no union connection with SWFRP pipe.

Special Contingencies**Amendment Reason:**

While working to install the new STP Sumps we found that the existing vent lines on the 5K PUL & 5K RUL tanks had buried unions. We eliminated the unions and made a solid 2" SWFRP connection at both.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: 847/612-6551
Email: tberg@perftank.com
Contractor License # IL881 Exp. 12/8/2024

Sincerely,



Daniel Starks