



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 6009205  
Permit #: 00137-2025UPG  
Request Rec'd: 02/06/2025  
Approval Date: 02/06/2025 DS  
Amended Date: 03/10/2025 DS  
Permit Expires: 08/06/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Midwest Petroleum Company 220 Old Meramec Station Rd. Manchester, MO 63021 (None) County Contact: Tony Koenig 636/220-3800	<b>FACILITY</b> - name and address where tanks are located: Midwest Petroleum #34 1200 Royal Heights Road Belleville, IL 62221 St. Clair County Contact: Fred Vesper 618/223-4222
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Out of service	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	New

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Bust concrete around existing tank manways, T1 Unlead and T2 Premium need the STP sumps installed and new STP subunits installed like for like, due to rust issues on risers. Risers will also be replaced. Concrete to be poured back around sumps and restore operation to all tanks.

**Special Contingencies**

**Amendment Reason:**

need to replace single wall spill bucket with a double wall on the premium fill due to broken plow ring. also have to replace the shear valve on dispenser 3/4 premium due to it sticking shut after line test.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
JDM Petroleum Service 220 Meramec Station Rd Manchester, MO 63021	Contact Person: Joe Devous Phone: 573/450-9775 Email: dustin.woeltje@jdmpetro.com Contractor License # IL002451 Exp. 7/15/2025

Sincerely,



Daniel Starks

<b>For Office Use Only</b>		
<b>Tank 1 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Piping	Not Installed STP/Tanktop Sump	Removing
<b>Tank 2 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Piping	Not Installed STP/Tanktop Sump	Removing