



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 6019213
Permit #: 00127-2025UPG
Request Rec'd: 02/03/2025
Approval Date: 02/04/2025 DS
Amended Date: 03/13/2025 DS
Permit Expires: 08/05/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Clinton County Oil Company, Inc. P.O. Box 155 Breesee, IL 62230 Clinton County Contact: Paul Rinella 618/526-7570	FACILITY - name and address where tanks are located: CC Food Mart 3410 George Street Highland, IL 62249 Madison County Contact: Gene Bickl 618/526-7570
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	8,000	Currently in use	Federal
5	Gasoline - Premium	10,000	Currently in use	Federal
6	Gasoline - Regular	15,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Summary of Work


Installing new dispenser sumps for dispensers 1/2, 3/4, 5/6 and 7/8. Those islands will be removed and new sumps to be set at grade level with no islands. Dispenser 9/10 and sump 9/10 will remain. A new section of APT XP150 pipe will be installed from dispenser sump 3/4 to dispenser sump 9/10 so a new 3+1 dispenser can be installed at that location to replace the existing 3+0 dispenser. Existing dispensers 1/2, 5/6 and 7/8 will also be replaced with new dispensers. Sump sensors with positive shut down will be installed in dispenser sumps 3/4 and 9/10.

Special Contingencies**Amendment Reason:**

Larry Warren said the piping must be double wall piping with sump sensors and positive shut down.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks