

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 7011747
Permit #: 00300-2025UPG
Request Rec'd: 03/06/2025
Approval Date:03/13/2025 DS
Permit Expires: 09/15/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKSCorporation, partnership, or other business entity:2 James, LLC5850 Hwy 145

5850 Hwy 145 Harrisburg, IL 62946 Saline County

Contact: Mike Duncan 618/694-9060

FACILITY

- name and address where tanks are located:

Mitchellville Country Store 5850 Highway 145 South Harrisburg, IL 62946 Saline County

Contact: Mike Duncan 618/252-6414

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Diesel Fuel	8,000	Currently in use	Federal
7	Gasoline - Premium	4,000	Currently in use	Federal
8	Diesel Fuel	30,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Automatic Tank Gauging Franklin Fueling	Replacing - Leak Detect - Tank - Automatic Tank
Tank	Systems EVO 400	Gauging Incon TS 1001

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	, , , , , , , , , , , , , , , , , , , ,	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection -	Automatic Tank Gauging Franklin Fueling	Replacing - Leak Detect - Tank - Automatic Tank
Tank	Systems EVO 400	Gauging Incon TS 1001

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	, , , , , , , , , , , , , , , , , , , ,	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001

Summary of Work

upgrading the existing Incon Ts-1001 to a EVO 400. New tank probes will be installed. The line leak detection was changed to mechanical leak detectors under permit #0115-2024UPG.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service

128 Millwell Drive

Maryland Heights, MO 63043

Contact Person: Terry Smith Phone: 314/241-3767

Email: cbayne@unitedpetro.com

Contractor License # IL002402 Exp. 2/10/2026

Sincerely, Daniel J. Starks

Daniel Starks