

## City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2021120
Permit #: 00248-2025UPG
Request Rec'd: 03/02/2025
Approval Date: 03/04/2025 SK
Amended Date:03/14/2025 SK
Permit Expires: 09/04/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Haramosh Management, LLC 4001 N. Laramie Ave. Chicago, IL 60641 Cook County

Contact: Sharafat Ali 630/247-3586

**FACILITY** 

- name and address where tanks are located:

Laramie Shell 4001 N. Laramie Ave. Chicago, IL 60641 Cook County

Contact: Sharafat Ali 630/247-3586Ext.127

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	8,000	Currently in use	Federal

## **Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

## Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
► Leak Detection - Piping	Sump Sensor	Reusing Existing

#### **Tank 3 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

#### **Summary of Work**

Changing the premum STP due to water leaking into sump. Changing the regular Spill bucket Thank you Innovative Constructions

# **Special Contingencies**

## **Amendment Reason:**

Spill bucket was mentioned for a wrong tank number

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185

Contact Person: Raju penumatsa

Phone: 630/747-3404

Email: iconstructions81@gmail.com

Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Sean Keane