



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3009229
Permit #: 00322-2025UPG
Request Rec'd: 03/19/2025
Approval Date: 03/19/2025 DS
Permit Expires: 09/19/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Gold Star FS, Inc. 13125 IL Hwy 81 Cambridge, IL 61238 Henry County Contact: Ethan Washburn 815/499-9766	FACILITY - name and address where tanks are located: Annawan Fuel 24 Rt 78 - North Canal St Annawan, IL 61234 Henry County Contact: Ethan Washburn 309/937-3369
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	B-11	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing existing single wall spill bucket with new grade level double wall spill bucket.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/344-0700 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Daniel Starks