



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3037183
Permit #: 00329-2025CAT
Request Rec'd: 03/20/2025
Approval Date: 03/20/2025 DS
Permit Expires: 09/22/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231 | FACILITY - name and address where tanks are located: Casey's #4630 113 Eastgate Drive Washington, IL 61571 Tazewell County Contact: Tianna Kimmons 515/446-6238 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|---|
| Corrosion Protection - Piping | Sacrificial Anode Cathodic Protection - Dispenser 7/8 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Dispenser 7/8 |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|---|
| Corrosion Protection - Piping | Sacrificial Anode Cathodic Protection - Dispenser 7/8 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Dispenser 7/8 |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|---|
| Corrosion Protection - Piping | Sacrificial Anode Cathodic Protection - Dispenser 7/8 | Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Dispenser 7/8 |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Installing sacrificial anodes at UDC 7/8 due to existing anodes missing.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Cheri McCoy
Phone: 309/694-8224
Email: Tom.Oltman@TotalPetroleum.net
Contractor License # IL1079 Exp. 2/8/2026

Sincerely,



Daniel Starks