



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 5022175  
Permit #: 00330-2025UPG  
Request Rec'd: 03/20/2025  
Approval Date: 03/20/2025 DS  
Permit Expires: 09/22/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Prairieland FS, Inc. 1132 Veterans Drive Jacksonville, IL 62650 Morgan County Contact: Keith Martin 217/243-6561	<b>FACILITY</b> - name and address where tanks are located: Milton Rt. 100 South, P.O. Box 256 Milton, IL 62352 Pike County Contact: Phil Ruble 217/723-4319
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	12,000	Currently in use	Federal
3	Gasoline - Regular	6,000	Currently in use	Federal
4	Gasoline - Regular	5,000	Currently in use	Federal

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
Diesel Satel	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser Diesel Satel Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Summary of Work**

INSTALL NEW SUMP SENSORS IN DISPENSER SUMPS AND TANK SUMPS. INSTALL POSITIVE SHUTDOWN

## Special Contingencies

### PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company  
2923 Gardner Expressway P. O. Box 1086  
Quincy, IL 62305

Contact Person: Marty Jackson  
Phone: 217/223-2190  
Email: kmajors@rlhoener.com  
Contractor License # IL2021 Exp. 5/22/2026

Sincerely,



Daniel Starks

### For Office Use Only

#### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

#### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

#### Dispenser Diesel Satel Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing