

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2031075
Permit #: 00332-2025UPG
Request Rec'd: 03/20/2025
Approval Date:03/20/2025 DS
Permit Expires: 04/01/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

7-Eleven, Inc.

3200 Hackberry Road - Gas Compliance

Irving, TX 75063 (None) County

Contact: Zachary Davis 937/203-7827

**FACILITY** 

- name and address where tanks are located:

7-Eleven #29910 398 S. Schmidt Rd. Bolingbrook, IL 60440

Will County

Contact: Robb Brian 757/490-6339

#### **Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Gasoline - Regular | 10,000   | Currently in use | Federal          |

### Tank 1 Equipment

| Equipment Type | Permit Equipment     | Action |
|----------------|----------------------|--------|
| Piping         | Flex Connector Steel | New    |

#### **Summary of Work**

Submitted Emergency Repair Request. Installing a new flex connector on Dispenser 1/2. Existing flex connector is leaking.

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:

Vaniel J. Starke

Anderson Pump Service, Inc. 19659 South 97th Avenue

Mokena, IL 60448

Contact Person: Ron Anderson

Phone: 708/560-5590

Email: Keith@Andersonpump.com

Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks